

## **MOUNTING INSTRUCTION NO.: 401/10**

### **SPRINKLER-COMPATIBLE MATERIAL: 401 EVENTEX AIR**

Mounting instruction No. 401/10 for sprinkler-compatible material, article '401 Eventex Air' for the horizontal installation underneath sprinkler systems.

With regard to the manufacturing and the mounting of '401 Eventex Air' underneath sprinkler systems, the following points have to be considered:

- A maximum free-spanning area (without bracings) of 30 m<sup>2</sup> is permitted.
- Sagging of '401 Eventex Air' has to be avoided through proper tensioning of the material.
- The sprinkler-compatible material has to be mounted horizontally.
- The material has to be used single-layered and can be bordered with a customary trimming tape for fixation. Mounting of the textile can be carried out using a welting band or applying eyelets on the bordering tape.
- The distance between the sprinkler spraying disc and the mounted sprinkler-compatible material is not permitted below 0.5 metres at any position.
- The material has to be tensioned equally in all directions in order to maintain the square shape of the mesh as well as the textile geometry.
- During assembly of the textile a ripping of the double web, hence a modification of the textile structure has to be avoided.
- Please make sure that a proper installation is not affected by any damages of the sprinkler-compatible textile (damages caused through installation, manufacturing).
- Any deviations of this guideline need a written approval by the manufacturer.

Graz, June 30, 2014

A handwritten signature in blue ink, appearing to read "Michael Pichler".

(DI Michael Pichler)